

Addendum

PROJECT: Renovation for Esports Jones Hall

ADDENDUM # 2

DATE: 4/26/2024

TO: ALL INTERESTED BIDDERS OF RECORD

BID NUMBER: B0028353

This Addendum # 2 forms part of the Contract Documents and modifies the original Bidding Documents. Acknowledge receipt of this addendum in the space provided on the Bid Form. Failure to acknowledge this addendum may subject Bidder to disqualification.

GENERAL INFO

1. The Bid Date has been extended to Thursday May 2, 2024. The times remain unchanged with Bids due into ISU Purchasing by 2:00pm and opened at 2:15pm via Teams conference call,

SPECIFICATION REVISIONS

1. None

DRAWING REVISIONS

None

QUESTION AND ANSWERS

- Q I have had a few painting subcontractors wanting a little more clarification on what is to be painted?
- A All of the walls on the esports area would be painted, both existing and new walls. The door frames would need to be painted for the doors in the esports room as well.
- Q The job specs list the carpet tile as an 18x18" product (square). However, the product that was selected is a rectangular plank product (25cm x 100cm). The Manufacturer just confirmed the size. Any special install instructions, or details we are missing on the product requested?
- A The Specifications are in error. The carpet shall be as called out on the Drawings which is 25cm x 1 meter.
- Q How are these railings/guardrails to be mounted?
- A The railing shall have a round metal flange with minimum of three bolts that will anchor to the wood platform and ramp.

OWNER COMMENT

1. The last date and time for questions has past. Questions received now may not receive consideration.

End of Addendum # 2