

Addendum

PROJECT: 3D Visualization Center (Science 158)

ADDENDUM # 2

DATE: 11/7/19

TO: ALL INTERESTED BIDDERS OF RECORD

BID NUMBER: B0026966

This Addendum # 2 forms part of the Contract Documents and modifies the original Bidding Documents. Acknowledge receipt of this addendum in the space provided on the Bid Form. Failure to acknowledge this addendum may subject Bidder to disqualification.

GENERAL INFO

1. The Bid Date remains unchanged set as November 12, 2019 at 2:00pm in ISU Purchasing Department.

SPECIFICATION REVISIONS

1. None

DRAWING REVISIONS

1. Clarification: The printer cables referenced in Plan Notes 16 & 17 on drawing E211 shall be wired with Cat 6A cabling.

QUESTION AND **ANSWERS**

1. Are the existing cables Cat6 or Cat6A? ***It's been determined that the existing cables are Cat 6. Remove all existing cables and provide new Cat 6A. (Ref. General Note 2, drawing E211)***
2. Do we need to supply a patch panel for the Cat6A or will the owner provide? ***Contractor shall provide new specified patch panels in existing data rack for new cables.***
3. Are Panduit faceplates and inserts required for the data ports or will the owner provide? ***Contractor shall provide specified faceplates and inserts for all data jacks.***
4. Will the owner provide the additional WAP? ***The Owner will provide and install the wireless access point. Contractor shall provide cabling. The one existing WAP will be reused, including its cable.***

OWNER COMMENT

1. The date and time for questions has passed. Any further questions received may not receive consideration.

End of Addendum # 2