



Indiana State University Federal Credit Union – Addition: A20-016

September 21, 2021

Addendum #3

The following items have been addressed in the below narrative as clarifications *and/or* additional information to the current set of construction documents.

Clarifications:

1. Brick budget from Addendum #2 is for material cost only. Contractor to include in base bid all associated costs for installing brick, including but not limited to labor, tax, additional materials required, etc
2. 5/8" OSB is acceptable in lieu of 3/4" exterior plywood sheathing
3. Revise wall section to use Tyvek wrap in place of 15# felt
4. Remove section 2.01 A.2 under Part 2 from Specification Section 081416 Wood Doors
Interior Wood Door Allowance: \$26,000.00
(does not include frames or hardware, reference plans for frames/hardware spec)

The items above are to be incorporated into this project immediately.

Thank you,

A handwritten signature in blue ink, appearing to read 'Matthew L. Holder'.

Matthew L. Holder, AIA

END OF ADDENDUM

ALL RECIPIENTS OF THIS ADDENDUM ARE TO CONTACT THE AUTHOR IMMEDIATELY WITH ANY COMMENTS AND/OR QUESTIONS REGARDING ITS CONTENTS