



**Indiana State University Federal Credit Union – Addition: A20-016**

September 7, 2021

**Addendum #1**

The following items have been addressed in the below narrative as clarifications *and/or* additional information to the current set of construction documents.

**Instruction to Bidders**

1. Bid Date Revised: due 4:00 pm (EST) on September 21, 2021 at the Holder Design office

**A0.0 Cover Sheet**

1. Replace sheet with attached sheet affixed with revision note '1 – Addendum 1 – 09.07.2021' Drawings have been added and/or revised per the drawing table matrix.

**A1.0 Architectural Site Plan**

1. Replace sheet with attached sheet affixed with revision note '1 – Addendum 1 – 09.07.2021'
2. Construction zone outlined

**A2.1 Foundation Plan**

1. Add attached sheet to set affixed with revision note '1 – Addendum 1 – 09.07.2021'

**A2.4 Roof Framing & Roof Plan**

2. Add attached sheet to set affixed with revision note '1 – Addendum 1 – 09.07.2021'

**A4.0 Sections & Details**

1. Replace sheet with attached sheet affixed with revision note '1 – Addendum 1 – 09.07.2021'
2. Sections revised

**Clarifications:**

1. Wood studs may be used on exterior walls in lieu of metal.
2. Contractor is responsible for repairing any damage to existing curbing and asphalt parking/drive-lanes that may occur during construction.
3. Contractor to provide and install temporary signage for directing traffic around construction zone.
4. Self-adhered flashings are acceptable

The items above are to be incorporated into this project immediately.

Thank you,

A handwritten signature in blue ink, appearing to read 'Matthew L. Holder'.

Matthew L. Holder, AIA

**END OF ADDENDUM**

ALL RECIPIENTS OF THIS ADDENDUM ARE TO CONTACT THE AUTHOR IMMEDIATELY WITH ANY COMMENTS AND/OR QUESTIONS REGARDING ITS CONTENTS












HOLDERDESIGN, INC.

24 South 5th Street  
Terre Haute, Indiana  
47807  
ph. 812.235.1300  
www.holderdesign.net

SCOPE DOCUMENT

THE DRAWINGS INDICATE THE GENERAL SCOPE OF THE PROJECT IN TERMS OF ARCHITECTURAL DESIGN CONCEPT, THE DIMENSIONS OF THE BUILDING, THE MAJOR ARCHITECTURAL ELEMENTS AND THE TYPE OF STRUCTURAL, MECHANICAL AND ELECTRICAL SYSTEMS AS SCOPE DOCUMENTS. THE DRAWINGS DO NOT NECESSARILY INDICATE OR DESCRIBE ALL WORK THAT IS REQUIRED FOR FULL PERFORMANCE AND COMPLETION OF THE REQUIREMENTS OF THE CONTRACT DOCUMENTS. ON THE BASIS OF THE GENERAL SCOPE INDICATED OR DESCRIBED, THE TRADE CONTRACTORS SHALL FURNISH ALL ITEMS REQUIRED FOR THE PROPER EXECUTION AND COMPLETION OF THE WORK.



*Matthew Holder*  
8/24/21

THE SEALS AND SIGNATURE(S) APPLY ONLY TO THE DOCUMENT TO WHICH THEY ARE AFFIXED AND WE EXPRESSLY DISCLAIM ANY RESPONSIBILITY FOR ALL OTHER PLANS, SPECIFICATIONS, ESTIMATES, REPORTS, OR OTHER DOCUMENTS OR INSTRUMENTS RELATING TO OR INTENDED TO BE USED FOR ANY PART OR PARTS OF THE PROJECT.

COPYRIGHT 2021 HOLDER DESIGN, INC.

DRAWN BY: AM  
CHECKED BY: MLH  
PLOT SCALE: AS NOTED  
DATE: 08.24.2021

INSTRUCTIONS FOR:  
**INDIANA STATE UNIVERSITY  
FEDERAL CREDIT UNION**  
TERRE HAUTE, INDIANA

SHEET DESCRIPTION: SECTIONS AND DETAILS

REVISIONS



ADDENDUM 1 - 09.07.2021

SHEET NO.

**A4.0**



JOB NO. A20-016

ASPHALT SHINGLES ON 15# ROOFING FELTS ON 1/2" O.S.B. DECK W/ "H"-CLIPS ON WD. TRUSSED@24" O.C.




1 WALL SECTION  
A4.0 SCALE: 1" = 1'-0"

ASPHALT SHINGLES ON 15# ROOFING FELTS ON 1/2" O.S.B. DECK W/ "H"-CLIPS ON WD. TRUSSED@24" O.C.




2 WALL SECTION  
A4.0 SCALE: 1" = 1'-0"

- NOTES:
- 1. CONTRACTOR TO MATCH EXISTING BRICK TYPE, COLOR, AND PATTERN
  - 2. BRICK TIES TO BE HOT DIPPED ADJUSTABLE TYPE
  - 3. INCLUDE ALL FLASHING, WEEPS, AND MORTAR NET



3 WALL DETAIL - 'A'  
A4.0 SCALE: 1" = 1'-0"



4 WALL DETAIL - 'B'  
A4.0 SCALE: 1" = 1'-0"

FOR BIDDING ONLY - NOT FOR CONSTRUCTION