# SECTION 235123 - GAS VENTS

## PART 1 - GENERAL

### 1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.2 SUMMARY

A. Section Includes:

1. Listed double-wall vents.

### 1.3 ACTION SUBMITTALS

A. Product Data: For each type of product.

1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for product.

B. Shop Drawings: For vents.

1. Include plans, elevations, sections, and attachment details.
2. Include details of equipment assemblies. Indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
3. Detail fabrication and assembly of hangers and seismic restraints.

### 1.4 INFORMATIONAL SUBMITTALS

A. Welding certificates.

B. Sample Warranty: For special warranty.

### 1.5 QUALITY ASSURANCE

A. Welding Qualifications: Qualify procedures and personnel according to the following:

1. AWS D1.1/D1.1M, "Structural Welding Code - Steel," for hangers and supports.
2. AWS D9.1/D9.1M, "Sheet Metal Welding Code," for shop and field welding of joints and seams in vents.

B. Certified Sizing Calculations: Manufacturer shall certify venting system sizing calculations.

PART 2 - PRODUCTS

2.1 LISTED TYPE B AND BW VENTS

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. American Metal Products.
2. Cleaver-Brooks.
3. FAMCO.
4. Hart & Cooley Inc.
5. Heatfab Saf-T Vent.
6. LSP Products Group.
7. Metal-Fab, Inc.
8. Van-Packer Company, Inc.
9. Duravent.
10. Cheminee Lining.

B. Description: Double-wall metal vents tested according to UL 441 and rated for 480 deg F continuously for Type B or 550 deg F continuously for Type BW; with neutral or negative flue pressure complying with NFPA 211.

C. Construction: Inner shell and outer jacket separated by at least a 1/4-inch airspace.

D. Inner Shell: ASTM B209, Type 1100 aluminum.

E. Outer Jacket: Aluminized steel.

F. Accessories: Tees, elbows, increasers, draft-hood connectors, terminations, adjustable roof flashings, storm collars, support assemblies, thimbles, firestop spacers, and fasteners; fabricated from similar materials and designs as vent-pipe straight sections; all listed for same assembly.
1. Termination: Round chimney top designed to exclude minimum 98 percent of rainfall.

2.2 LISTED TYPE L VENTS

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. American Metal Products.
2. FAMCO.
3. Heatfab Saf-T Vent.
4. LSP Products Group.
5. Metal-Fab, Inc.

6. Van-Packer Company, Inc.
7. Duravent.
8. Cheminee Lining.

B. Description: Double-wall metal vents tested according to UL 641 and rated for 570 deg F continuously or 1700 deg F for 10 minutes; with neutral or negative flue pressure complying with NFPA 211.

C. Construction: Inner shell and outer jacket separated by at least a 1-inch airspace filled with high-temperature, mineral-wool insulation.

D. Inner Shell: ASTM A666, Type 304 stainless steel.

E. Outer Jacket: Stainless steel.

F. Accessories: Tees, elbows, increasers, draft-hood connectors, terminations, adjustable roof flashings, storm collars, support assemblies, thimbles, firestop spacers, and fasteners; fabricated from similar materials and designs as vent-pipe straight sections; all listed for same assembly.
1. Termination: Round chimney top designed to exclude 98 percent of rainfall.

## 2.3 LISTED SPECIAL GAS VENTS

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Heatfab Saf-T Vent.
2. Metal-Fab, Inc.
3. Duravent.
4. Cheminee Lining.

B. Description: Double-wall metal vents tested according to UL 1738 and rated for 480 deg F continuously, with positive or negative flue pressure complying with NFPA 211.

C. Construction: Inner shell and outer jacket separated by at least a 1/2-inch airspace.

D. Inner Shell: ASTM A959, Type 29-4C stainless steel.

E. Outer Jacket: Stainless steel.

F. Accessories: Tees, elbows, increasers, draft-hood connectors, terminations, adjustable roof flashings, storm collars, support assemblies, thimbles, firestop spacers, and fasteners; fabricated from similar materials and designs as vent-pipe straight sections; all listed for same assembly.
1. Termination: Round chimney top designed to exclude minimum 98 percent of rainfall.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

A. Examine areas and conditions for compliance with requirements for installation tolerances and other conditions affecting performance of work.

B. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 APPLICATION

A. Listed Type B and BW Vents: Vents for certified gas appliances.

B. Listed Type L Vent: Vents for low-heat appliances.

C. Listed Special Gas Vent: Condensing gas appliances.

### 3.3 INSTALLATION OF LISTED VENTS

A. Coordinate installation of roof curbs, equipment supports, and roof penetrations. These items are specified in Section 077200 "Roof Accessories."

B. Comply with minimum clearances from combustibles and minimum termination heights according to product listing or NFPA 211, whichever is most stringent.

C. Seal between sections of positive-pressure vents according to manufacturer's written installation instructions, using sealants recommended by manufacturer.

D. Support vents at intervals recommended by manufacturer to support weight of vents and all accessories, without exceeding appliance loading.

E. Lap joints in direction of flow.

### 3.4 CLEANING

A. After completing system installation, including outlet fittings and devices, inspect exposed finish. Remove burrs, dirt, and construction debris, and repair damaged finishes.

END OF SECTION 235123